



Dokumentnr: ND-TF-TK-002

Dat 2015-12-10

Reviderad:

Adm: Andreas Långström

Sammanställning ljudprestanda Produktserie Tanum

Produkt / Modul	Glasrecept Counter	Glas (ut - in)	Rw (dB)	Rw+Ctr (dB)	C;Ctr (dB)	Protokoll nr	Bilaga
VF 12,5x15	2244	4-16-4-16-4	33	27	-2;-6	5P07328-A	1
VF 12,5x15	2265	6,38-12-4-16-4	36	30	-2;-6	5P07328-A	2
VF 12,5x15	3407	SS 8,38-12-4-15-4	38	32	-2;-6	5P07328-A	3
VF 12,5x15	3411	SS 8,38-10-4-12- SS 8,38	40	35	-1;-5	5P07328-A	4
Alu-VF 12,5x15	3347	6-12-4-16-4	35	29	-2;-6	5P07328-A	5
Alu-VF 12,5x15	2265	6,38-12-4-16-4	36	30	-2;-6	5P07328-A	6
Alu-VF 12,5x15	3411	SS 8,38-10-4-12- SS 8,38	40	36	-1;-4	5P07328-A	7
Alu-VF 12,5x15	3407	SS 8,38-12-4-15-4	37	31	-2;-6	5P07328-A	8
FF 12,5x15	2244	4-16-4-16-4	31	26	-1;-5	5P07328-A	9
FF 12,5x15	3411	SS 8,38-10-4-12- SS 8,38	43	34	-3;-9	5P07328-A	10
FDB 10x21/VF15	2244	4-16-4-16-4	31	27	-2;-4	5P07328-A	11
FDG 10x21	3407	SS 8,38-12-4-15-4	39	32	-2;-7	5P07328-A	12
FDG 10x21	3333	4-16-4-16-4	34	28	-2;-6	5P07328-A	13
FDG 10x21	3347	6-12-4-16-4	37	31	-2;-6	5P07328-A	14
Alu-FDB 10x21VF15	2244	4-16-4-16-4	31	26	-2;-5	5P07328-A	15
Alu-FDG 10x21	3333	4-16-4-16-4	33	27	-1;-6	5P07328-A	16