

Sound reduction index in accordance with PN - EN ISO 10140-2 (2011)

Laboratory measurements of airborne sound insulation of building elements

Client: **NorDan Sp. z o.o.**

Measurement date: **24.09.2021**

Address: **Powodowo 54, 64-200 Wolsztyn**

Test specimen: **Wooden fixed frame**

Pi LNR: **10**

Construction: **TL, ND Ntech Villa Fixed frame 105mm**

Glazed by:

66.2 SR Foil / 24 Ar / 8

Frame thickness: **105 mm**

Description of the test facility, test specimen and test arrangement:


Size of test specimen: **1230 x 1480 mm**

Test specimen mounted by: **NorDan Sp. z o.o.**

The surface area of test specimen: **1,90 m²**

Parameter	Receiving room	Source room
Air temp. [°C]	19,5	19,5
Humidity [%]	55	55
Pressure [hPa]	1009	1009
Volume [m ³]	372	324

Frequency [Hz]	Test results with uncertainty	
	R [dB]	U _{CR} [dB]
50	22,2	3,3
63	29,7	2,2
80	21,9	1,8
100	25,3	2,3
125	29,2	1,8
160	29,8	1,6
200	30,6	1,5
250	36,9	1,0
315	39,3	1,2
400	42,5	1,0
500	44,0	0,9
630	44,5	0,8
800	43,3	0,9
1000	44,2	0,7
1250	42,2	0,7
1600	40,1	0,7
2000	40,9	0,8
2500	44,3	0,8
3150	46,8	0,9
4000	48,0	0,9
5000	49,1	1,0



Measurement uncertainty of sound reduction U_{CR}
Confidence level 95% at coverage factor, k=2

Weighted sound reduction index in accordance with PN-EN ISO 717-1:2021-06E

R_w (C; C_{tr}) = 43 (-2; -4) dB

C₅₀₋₃₁₅₀ = -2 dB

C₅₀₋₅₀₀₀ = -1 dB

C₁₀₀₋₅₀₀₀ = -1 dB

C_{tr, 50-3150} = -6 dB

C_{tr, 50-5000} = -6 dB

C_{tr, 100-5000} = -4 dB

R_w = 43,5 dB

GRYFITLAB Sp. z o.o. Laboratory of Acoustics

No. of test specimen: GLA-1559.23 / 21

Date: 24.09.2021

Signature: Robert Dybicz

Figure 13 Characteristics of airborne sound insulation of test specimen No. GLA-1544.23 / 21